

## WATER QUALITY TEST RESULTS

Contaminant	Violation Y/N	Level Detected	Units of Measurement	MCLG	MCL	Likely Source of contamination			
<b>Radioactive Contaminants:</b>									
Alpha emitters Test Results Yr. 2000	No	0.19	pCi/L	0	15	Erosion of natural deposits			
<b>Inorganic Contaminants:</b>									
Copper Test Results Yr. 2002	No	0.09 No Samples exceeded the action level	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits			
Fluoride Test Results Yr. 2002	No	Range = ND-0.2 Highest Level detected = 0.2	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories			
Lead Test Results Yr. 2002	No	8 No samples exceeded the action level	ppb	0	AL = 15	Corrosion of household plumbing systems, erosion of natural deposits			
<b>Volatile Organic Contaminants:</b>									
TTHM [Total trihalomethanes] Test Results Yr. 2003	No			ppb	N/A	80	By-product of drinking water disinfection		
	Qtr of 2002		Qtr 2003						
	Site#	2	3	4	1	2		3	4
	1	7	18	1	ND	ND		ND	5
	2	1	4	ND	7	1		2	2
	3	2	10	ND	18	4		10	3
4	2	3	2	7	1	6	10		
Qtr									
Avg	3	9	1	8	2	4	5		
Rolling									
Annual Avg					5	5	4	5	
Highest Average = 8, Range = ND - 18									